




Tender-6
Supply, Fabrication, Erection, of Steel Shed Works for
Construction of STD Facility, Sahiwal




May 21, 2018

Clarification # 2

Pursuant to IB.8.1 of Tender Document for Supply, Fabrication, Erection of Steel Shed Works for Construction of STD Facility, Sahiwal. The clarification response are as follow.

Sr	Clarification	Answer
1	We want to submit an alternate proposal for the STD Facility tender as from the tender drawings the sections used are standard rolled section which can be well economized using prefabricated steel sections. Please confirm.	Please See IB.16 Alternate Proposals by the Bidder. The bidder may submit in ADDITION to his bid in strict compliance with the bidding document may submit in SEPARATE SEALED ENVELOPES improved section profile by altering the member sizes & thickness to provide a safer & more economical solution provided that the safety and integrity of the structure not to be compromised & same shall be proved by SAP2000 structural models submitted to consultant design team along with the bid.
2	The roof slope mentioned on page 114 in building parameters is 1 : 15 whereas the roof slope in the drawings for PEB Shed is 2.1 : 15. Please confirm which roof slope is to be followed.	The slope mentioned in PEB Shed drawings should be followed
3	Also confirm if the same roof slope is to be used for the design of Parking shed as well.	The slope mentioned in Parking Shed drawing should be followed
4	On Page number 31 of tender documents in the requirement for engineers registered with PEC, it is requested that you allow us an option to use Mechanical / Metallurgical engineers registered with PEC since we are bidding for mechanical and steel works only	In addition to Civil Engineer, Mechanical / Metallurgical engineers may also be provided but registration with Pakistan Engineering Council is a must along with other criteria as mentioned in bidding document.
5	On page no 33, average monthly bank balance is mentioned. Please clarify this clause (w.r.t Rs 50 million or more). We are unsure what documents are required.	Required Document is already mentioned under the table as a "Note". Bank Balance / Statements for last six months are to be provided.


Chief Executive Officer
The Urban Unit

	NAME	SIG.	DATE
Draft	Mughes		21/5/18
Review I	N. Khan		21/5/18
Review II	Abid		21/5/18
Approved			